

CERTIFICATE

TÜV NORD CERT GmbH
herewith declares that

Elit Solar Enerji Teknolojileri San. ve Tic. Ltd. Şti.
5.OSB, 83501 Nolu Cadde No:43,
27600 Şehitkamil / Gaziantep,
Türkiye

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules



Valid from: 2023-09-22

Valid until: 2028-09-21

Certification program:	P12-VA-01 Rev. 17 09.20
Certification fundamental(s):	IEC / EN 61215-1:2016; IEC / EN 61215-1-1:2016; IEC 61215-2:2016 / EN 61215-2:2017 + AC:2017 + AC:2018; IEC 61730-1:2016 / EN IEC 61730-1:2018 + AC:2018; IEC 61730-2:2016 / EN IEC 61730-2:2018 + AC:2018.
Registered No.:	44 780 23 406749 - 313
Manufacturer:	see Annex 1
Test Report No.:	492012705.001
File No.:	PVP01063/23P-01




TÜV NORD CERT GmbH
Certification Body
Consumer Products

Essen, 2023-09-22

Please also pay attention to the information stated overleaf.

Manufacturer:

Manufacturer: **Elit Solar Enerji Teknolojileri San. ve Tic. Ltd. Şti.**
5.OSB, 83501 Nolu Cadde No:43, 27600 Şehitkamil / Gaziantep, Türkiye
Factory inspection report no.: 862010819.001

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:	PV Modules with 182mm Half-Cut Mono-crystalline Silicon Solar Cells: 144 cells: ELT 72-182M10-BF xxxW (xxx = 540-570, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	30A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	1600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Module types:	PV Modules with 182mm Half-Cut Mono-crystalline Silicon Solar Cells: 120 cells: ELT 60-182M10-BF xxxW (xxx = 450-475, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	25A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	1600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



TÜV NORD CERT GmbH
Certification Body
Consumer Products