

CERTIFICATE

TÜV NORD CERT GmbH
herewith declares that

Elit Solar Enerji Teknolojileri San. ve Tic. Ltd. Şti.
5.OSB, 83501 Nolu Cadde No:43,
27600 Şehitkamil / Gaziantep,
Türkiye

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules




Valid from: 2023-10-17

Valid until: 2028-10-16

Certification program: P12-VA-01 Rev. 17 09.20
Certification fundamental(s): IEC 61701:2020
Remark: Test Method 6
Test duration: 1344 hours
Registered No.: 44 780 23 406749 - 358
Manufacturer: see Annex 1
Test Report No.: 492012749.001
File No.: PVP01063/23P-02




TÜV NORD CERT GmbH
Certification Body
Consumer Products

Essen, 2023-10-17

Please also pay attention to the information stated overleaf.

Anlage 1 zum Zertifikat Nr.: / Annex 1 to Certificate No.: 44 780 23 406749 - 358

Seite / Page 1 von / of 1

Aktenzeichen: / File reference: PVP01063/23P-02

2023-10-17

Manufacturer:

Manufacturer :

Elit Solar Enerji Teknolojileri San. ve Tic. Ltd. Şti.

5.OSB, 83501 Nolu Cadde No:43, 27600 Şehitkamil / Gaziantep, Türkiye

Factory inspection report no.:

862010819.001

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types: **PV Modules with 182mm Half-Cut Mono-crystalline Silicon Solar Cells:**
144 cells: ELT 72-182M10-BF xxxW (xxx = 540-570, in increment of 5)

Maximum system voltage: 1500V

Fuse rating: 30A

Application class: Class A

Electrical protection class: Class II

Module types: **PV Modules with 182mm Half-Cut Mono-crystalline Silicon Solar Cells:**
120 cells: ELT 60-182M10-BF xxxW (xxx = 450-475, in increment of 5)

Maximum system voltage: 1500V

Fuse rating: 25A

Application class: Class A

Electrical protection class: Class II

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.